




9-Point Testing Of Needle Detector

Refer to your product safety manual.



Test at 9 points EVERY time.

Note: Needle detector must be calibrated at least 3 times per



Tools for 9-point test

1. Test card 1.2mm* or 1.0mm* diameter ferrous metal standard dependent on buyer's requirement

2. Calibration block 60 x 60 x 90 mm

8-hour shift

Note: Place the test card to the corresponding position by using the calibration block (see picture on the right) to test the machine sensitivity.

Step 1 Place the test card onto the conveyor belt to test A1, A2 and A3. Note: Calibration block is not required.

Step 2

Place the test card onto the calibration block (see picture below) then onto the conveyor belt to test A4, A5 and A6.

Note: test card is positioned about 6cm above the conveyor belt



DO NOT continue if ANY point not detected.


	Left	Centre	Right		
Тор	A7 🗸	А8 🗸	A9 🗸		
Centre	A4 🗸	А5 🗸	A6 🗶		
Bottom	A1 🗸	A2 🗸	АЗ 🗸		



Note: A6 not detected is an example only. It can be on other positions, too.







Step 3

Place the test card onto the calibration block (see picture below) then onto the conveyor belt to test A7, A8 and A9. Note: test card is positioned about 9cm above the conveyor belt.






In case any point (e.g. A6) not detected, re-test the failed point(s).



Unit 14, 6/F., Worldwide Industrial Centre, 43-47 Shan Mei Street, Fotan, Shatin, Hong Kong T: +852 27420018 F: +852 27420053 info@hcl-asia.com.hk

www.hcl-asia.com.hk



Record detection result :

\checkmark	YES or >	<pre> NO </pre>
	Loft	Contro

	Left	Centre	Right
Тор	A7 🗸	A8 🗸	A9 🗸
Centre	A4 🗸	A5 🗸	A6 🗸
Bottom	A1 🗸	A2 🗸	A3 🗸

Note: If ALL ✓ then proceed.